



KET-MPA-000

Applications
Accounting

Flow meter for compressed air and gas insertion or inline

- Max pressure 16 bar
- Reliability of the measurement
- Can be installed in a pressurised system without interruption of flow
- Non-return protection

The **KET-MPA** flowmeter is based on the **thermal mass flow** rate and is ideal for measuring the flow of **compressed air and gas**. Available as an insert for pipes from DN50 (2") to DN300 (12") or in-line for pipes from DN15 (1/2") to DN40 (1 1/2"). With the KET-MPA, the consumption of compressed air, nitrogen, CO2 or other non-corrosive and non-flammable gases can be measured up to a pressure of 16 bar (232 PSI). The insertion flow meter can be mounted/disassembled under pressure **without interruption of the flow**, safely with non-return protection.

Technical Features	
General specifications	Protection Range: Inline: IP65 Operative Temperature: -20 ÷ +80 °C Storage Temperature: -20 ÷ +60 °C Relative Humidity: MAX 99% not condensing
Power supply	Supply Voltage: 18 ÷ 30 VAC / VDC Consumption: Max 200 mA Connectors types: Cable gland M16x1.5 (optional connector M12x1 8pol.)
Rs485 interface	Supported Protocols: ModBUS RTU
Analog inputs	Analog Inputs: 4 - 20 mA for pressure sensor
Digital outputs	Channels: Pulse of length 0.02 ÷ 2 sec
Analog outputs	Output Type: Voltage: 0 ÷ 10 V max. 1 mA; Current: 0 ÷ 20 mA and 4 ÷ 20 mA RL<500 Ohm
Rele' outputs	Voltage Output: 44 VDC Maximum Rated Current: 500 mA
Compressed air flow meter	Measurand: Volumetric flow at standard conditions acc. DIN 1343; P0 = 1013.25 mbar (14.7 PSI); T0 = 0 °C (32 °F) Measure Range: Insertion: 0.2 ÷ 200 Nm³/s; Inline: varies according to DN, from 0.32 ÷ 63 Nm³/s (DN15) to 2.26 ÷ 452 Nm³/s (DN40) Accuracy: ± (1.5% of measuring value + 0.8% of full scale) Temperature Coefficient: ± (0.1% of measuring value / °C) Pressure Coefficient: +0.5% of measuring value / bar Response Time: < 1 s Tube Diameter: Insertion: Ø 50 ÷ 300 mm; Inline: Ø 15 ÷ 40 mm
Certifications	Referends Standard: EN61326-1, EN61326-2-3 Approvals: CE